



County of Riverside
DEPARTMENT OF ENVIRONMENTAL HEALTH

P.O. BOX 7909 • RIVERSIDE, CA 92513-7909

STEVE VAN STOCKUM, DIRECTOR

Date: February 2nd, 2018

System No. 3301011

Stone Creek Water Company, INC
72810 Ambrosia St.
Palm Desert CA, 92260-5971

Enclosed is Citation No. 05_63_18C_003 issued to Stone Creek Water Company. Please note that there are certain deadlines associated with this Citation.

Any person who is aggrieved by a Citation issued by the Riverside County LPA may file a petition with the State Water Resources Control Board (State Water Board) for reconsideration of the Citation. Petitions must be received by the State Water Board within 30 calendar days of the issuance of the Citation. The date of issuance is the date when the Riverside County LPA mails or serves a copy of the Citation, whichever occurs first. If the 30th day falls on a Saturday, Sunday, or state holiday, the petition is due the following business day. Petitions must be received by 5:00 p.m. Information regarding filing petitions may be found at:

http://www.waterboards.ca.gov/drinking_water/programs/petitions/index.shtml

If you have any questions regarding this matter, please contact this Department at (951) 955-8980

Sincerely,

Daisy Ciudad Real M.P.H., R.E.H.S
Environmental Health Specialist

Certified Mail: 7017 3040 0000 8560 8489



County of Riverside
DEPARTMENT OF ENVIRONMENTAL HEALTH

P.O. BOX 7909 • RIVERSIDE, CA 92513-7909

STEVE VAN STOCKUM, DIRECTOR

**CITATION FOR NONCOMPLIANCE – WATER SYSTEM NO. 3301690
NO. 05_63_18C_003**

Date: February 2nd, 2018

Re: Stone Creek Water Company, INC.
System No. 3301011

To: Stone Creek Water Company, INC.
72810 Ambrosia ST
Palm Desert CA, 92260-5971

Section 116650, Article 9, Chapter 4, Part 12, Division 104 of the California Health and Safety Code (H&S Code), authorizes the issuance of a citation for failure to comply with the requirements of the California Safe Drinking Water Act, or any regulation, standard, permit order issued there under.

VIOLATION

The Department of Environmental Health (Department), hereby issues a citation to Stone Creek Water Company for the following violations:

Title 22 of the California Code of Regulations (CCR), Section 64432 Specifically, Stone Creek Water System failed to sample well #2 for Inorganic Chemicals between the period of 2015-2017. All public water systems using groundwater shall monitor for Inorganic Chemicals every three years.

Title 22 of the California Code of Regulations (CCR), Section 64449 Specifically, Stone Creek Water System failed to sample well # 2 for Secondary Drinking Water Standards between the period of 2015-2017. All public water systems using groundwater shall monitor for Secondary Drinking Water Standards every three years.

CHRONOLOGY OF EVENTS

The water system consists of two drilled wells. Well #1 is 450 feet deep, 8 inches in diameter and serviced by a 3 hp submersible pump. Well #2 is 315 feet deep, 6 inches in diameter and is serviced by a 3 hp submersible pump.

The system was last inspected on 4/01/2017. At that time the operator and owner was provided a sampling schedule with dates of when sampling for each well was due. The operator and owner

were provided a copy of the inspection report on 5/24/2017. The report also included the schedule for sampling with dates of compliance.

RECENT HISTORY

Stone Creek Failed to sample well # 2 for Inorganic and Secondary Drinking Water Standards as required during the period of January 2015- December 2017.

DIRECTIVES

Submit results for Inorganics and Secondary Drinking Water Standard to this Department once you have been notified by the laboratory.

Sample active wells for Inorganics and Secondary Drinking Standards every 3 years and stand-by wells every 9 years. Failure to comply could result in citations with penalty.

This is considered a monitoring and reporting (M&R) violation and requires public notification utilizing the Tier 3 notification method, which is notification to the consumers. All consumers served by this water system must be notified of this violation, as required in Section 64463.4. Attached is a notification form containing the language that is required in Section 64465. The notice must be distributed to all customers and included in the 2017 CCR. The notice must be completed by July 1st, 2018. Submit a Proof of Notification to this Department once the notice has been delivered to your water consumers.

FURTHER ENFORCEMENT ACTION

Failure to comply with this notice and/or failure to comply with Title 22 of the California Code of Regulations may result in an administrative office hearing and assessment of administrative penalties. This Department does not waive any further enforcement action by issuance of this citation.

If you have any questions, please contact this Department at (951) 955-8980



Daisy Ciudad Real, M.P.H., R.E.H.S
Environmental Health Specialist

Attachments:
Tier 3 Monitoring Notice
Proof of Notification

Certified Mail: 7017 3040 0000 8560 8489